

CHEM RIGHT LABORATORIES, INC.

117 N. Main St. - Maquoketa, IA 52060 - IA Lab# 379 - Phone 563-652-4226 - Fax 563-652-6137

TESTING REPORT

Elizabeth Townsend
Jackson County Health Department
201 W. Platt
Maquoketa, IA 52060

Report Date: 06/15/22
Report Number: 24488
Sample Received: 06/14/22
Order Number: 23635

<u>Sample ID</u>	<u>Parameter</u>	<u>Sample Matrix</u>	<u>Analysis Time</u>	<u>Method</u>	<u>Analyst</u>	<u>Codes</u>	<u>Result</u>	<u>Units</u>
Bradley Bowman (kitchen sink) 10592 90th St. Maquoketa, IA								
220614-W-3523	Coliform (e-coli) MPN	Water	06/14/22 14:10	9223B-QT	SG/JD	ND <	1.0	cfu/100 ml
220614-W-3523	Coliform (total) MPN	Water	06/14/22 14:10	9223B-QT	SG/JD	ND <	1.0	cfu/100 ml
220614-W-3523	Nitrate-N	Water	06/15/22 15:02	300.0	SG/JD		1.7	ppm

Code Description

ND Non-Detect. The value given is the detection limit.

No coliform bacteria was detected.
The infant health advisory limit for nitrate-N is 10 ppm.

Susan E. Gossman, Operations Manager

06/15/2022

Technical Review

Date

Page 1