

CHEM RIGHT LABORATORIES, INC.

117 N. Main St. - Maquoketa, IA 52060 - IA Lab# 379 - Phone 563-652-4226 - Fax 563-652-6137

TESTING REPORT

Elizabeth Townsend
Jackson County Health Department
201 W. Platt
Maquoketa, IA 52060

Report Date: 09/25/25
Report Number: 30447
Sample Received: 09/23/25
Order Number: 29638

<u>Sample ID</u>	<u>Parameter</u>	<u>Sample Matrix</u>	<u>Analysis Time</u>	<u>Method</u>	<u>Analyst</u>	<u>Codes</u>	<u>Result</u>	<u>Units</u>
c/o Chuck Swager (k-tap) 25483 134th St Maquoketa, IA								
250923-W-1355	Coliform (e-coli) MPN	Water	09/23/25 10:15	9223B-QT	KD	ND <	1.0	cfu/100 ml
250923-W-1355	Coliform (total) MPN	Water	09/23/25 10:15	9223B-QT	KD	ND <	1.0	cfu/100 ml
250923-W-1355	Nitrate-N	Water	09/23/25 11:18	300.0	SG/KD		12	ppm

Code Description

ND Non-Detect. The value given is the detection limit.

No coliform bacteria was detected.

Nitrate-N level greater than 10 ppm exceeds the infant health advisory.

Susan E. Gossman, Operations Manager

Technical Review

09/25/2025

Date

Page 1